

Message Text

CONFIDENTIAL

PAGE 01 KARACH 00325 221058Z

ACTION OC-06

INFO OCT-01 NEA-10 ISO-00 CCO-00 OCL-00 FBOE-00 SY-05

A-01 /023 W

-----104427 221100Z /11

R 220516Z JAN 78

FM AMCONSUL KARACHI

TO SECSTATE WASHDC 2833

INFO AMEMBASSY NEW DELHI

C O N F I D E N T I A L KARACHI 0325

NEW DELHI FOR ATO

E.O. 11652: N/A

TAGS: AFAC, ABLD, ASEC

SUBJECT: CCC RENOVATIONS

REF: STATE 002123

1. POST WILL ARRANGE TO HAVE COVERED STORAGE
FOR SHIELDED ENCLOSURE UPON ARRIVAL OF SHIPMENT.

2. CONSTRUCTION SPECIFICATION E.1. SPECIFIES
REMOVAL OF MODEL II INCINERATOR FROM ROOM 8. POST
PREFERS TO RETAIN THIS INCINERATOR. TO INSURE
EMERGENCY DESTRUCT CAPABILITY, GFE SEM MODEL 1012
DISINTEGRATOR SHOULD BE INSTALLED IN ROOM 11 INSTEAD
OF ROOM 8. CONGEN PLANS TO CONSTRUCT DIVIDING WALL
SEPARATING THE TWO DISINTEGRATORS. SEPARATE ENTRANCES
WILL BE AVAILABLE TO ALLOW ACCESS TO EACH MACHINE BY
TCU AND C&R PERSONNEL. CABLE FEED-THRU IS ALREADY
AVAILABLE IN ROOM 8 FOR POWER OF SPECIAL A/C UNIT.
CHIMNEY OPENING CAN BE RETAINED FOR THE
INCINERATOR INSTEAD OF CABLE FEED-THRU.
TCU SUPERVISOR CONCURS IN THIS RECOMMENDATION.

CONFIDENTIAL

CONFIDENTIAL

PAGE 02 KARACH 00325 221058Z

3. SUGGEST YOU RECONSIDER SPECIFICATION H.9
FOR 1/4 INCH STEEL FOR NEW SOUTH PENTHOUSE
WALL. COST WOULD BE MORE THAN DOUBLE THAT OF
A REINFORCED CONCRETE WALL WITH NO INCREASED
SECURITY BENEFIT. POST PROPOSES 6 INCH RC WALL
REINFORCED WITH 1/4 INCH STEEL RODS AT 8 INCH
CENTERS. EXCESSIVE QUANTITY OF STEEL SUPPORTS

REQUIRED TO SUPPORT STEEL WALL AND DIFFICULTY
IN ERECTING STEEL SHEETS ARE ADDITIONAL FACTORS
WHICH FAVOR AN RC WALL. LARGEST SIZE STEEL
SHEETS AVAILABLE ARE 3 FEET BY 6 FEET. THESE
REQUIRE WELDING AND STEEL ANGLE SUPPORTS AT EACH
JOINT.

4. OUTER DOORS PRESENTLY INSTALLED IN PENTHOUSE
WALL ARE CONSTRUCTED OF DOUBLE SHEETS OF 1/8 INCH
STEEL. THIS CONSTRUCTION ALREADY APPEARS TO MEET
THE SPECIFIED THICKNESS OF 1/4 INCH STEEL FOR THE
NEW DOORS. PLEASE ADVISE.

5. COST ESTIMATE FOR CONTRACTOR PORTION OF WORK
WILL BE SUBMITTED WITHIN 14 DAYS.
MOORE

CONFIDENTIAL

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01 jan 1994
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Draft Date: 22 jan 1978
Decaption Date: 01 jan 1960
Decaption Note:
Disposition Action: RELEASED
Disposition Approved on Date:
Disposition Case Number: n/a
Disposition Comment: 25 YEAR REVIEW
Disposition Date: 20 Mar 2014
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1978KARACH00325
Document Source: CORE
Document Unique ID: 00
Drafter: n/a
Enclosure: GS DG ALTERED
Executive Order: GS
Errors: N/A
Expiration:
Film Number: D780033-0396
Format: TEL
From: KARACHI
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1978/newtext/t19780136/aaaabeiq.tel
Line Count: 78
Litigation Code IDs:
Litigation Codes:
Litigation History:
Locator: TEXT ON-LINE, ON MICROFILM
Message ID: f10825e1-c288-dd11-92da-001cc4696bcc
Office: ACTION OC
Original Classification: CONFIDENTIAL
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 2
Previous Channel Indicators: n/a
Previous Classification: CONFIDENTIAL
Previous Handling Restrictions: n/a
Reference: 78 STATE 2123
Retention: 0
Review Action: RELEASED, APPROVED
Review Content Flags:
Review Date: 12 may 2005
Review Event:
Review Exemptions: n/a
Review Media Identifier:
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
SAS ID: 3733928
Secure: OPEN
Status: NATIVE
Subject: CCC RENOVATIONS
TAGS: AFAC, ABLD, ASEC
To: STATE
Type: TE
vdkgvwkey: odhc://SAS/SAS.dbo.SAS_Docs/f10825e1-c288-dd11-92da-001cc4696bcc
Review Markings:
Sheryl P. Walter
Declassified/Released
US Department of State
EO Systematic Review
20 Mar 2014
Markings: Sheryl P. Walter Declassified/Released US Department of State EO Systematic Review 20 Mar 2014